

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com				
Certificate No.:	IECEx FME 14.0001X	Page 1 of 4	Certificate history:	
Status:	Current	Issue No: 5	Issue 4 (2018-04-26) Issue 3 (2016-05-26) Issue 2 (2015-11-09)	
Date of Issue:	2019-11-30		Issue 1 (2015-06-25) Issue 0 (2014-06-25)	
Applicant:	LumaSense Technologies GmbH Kleyerstrasse 90, Frankfurt D-60326 Germany			
Equipment:	3909010, E ² T Pulsar 4 Advanced Infra-Red	Pyrometer & 3909020, E²T Pulsar 4 Infra-Re	d Pyrometer	
Optional accessory:				
Type of Protection:	Flameproof 'd'			
Marking:	Ex db IIB+H ₂ T4 Gb Ta = -40°C to +60°C IP66			
Approved for issue or Certification Body:	h behalf of the IECEx	Andrew Was		
Position:		Certification Manager		
Signature: (for printed version)				
Date:				
2. This certificate is	d schedule may only be reproduced in full. not transferable and remains the property of the uthenticity of this certificate may be verified by by:			
FM Approvals Lt Voyager Place Maidenhead Berkshire SL6 2PJ United Kingdom		\sim	Approvals	



Certificate No .:	IECEx FME 14.0001X	4	Page 2 of 4			
Date of issue:	2019-11-30		Issue No: 5			
Manufacturer:	LumaSense Technol Kleyerstrasse 90, Fran Germany					
Additional manufacturing locations:						
This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended						
STANDARDS : The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards						
IEC 60079-0:2017 Edition:7.0	Explosive atmosphere	es - Part 0: Equipment - General requiren	nents			
IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d" Edition:7.0						
This Certificate does not indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.						
TEST & ASSESSMENT REPORTS: A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:						
Test Reports:						
GB/FME/ExTR14.000 GB/FME/ExTR14.000		GB/FME/ExTR14.0001/01 GB/FME/ExTR14.0001/05	GB/FME/ExTR14.0001/02 GB/FME/ExTR14.0001/06			
Quality Assessment F	Report:					
GB/FME/QAR14.000	4/02					



Certificate No.: IECEx FME 14.0001X

Date of issue: 2019-11-30

Page 3 of 4

Issue No: 5

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

3909010, E²T Pulsar 4 Advanced Infra-Red Pyrometer & 3909020, E²T Pulsar 4 Infra-Red Pyrometer

The LumaSense E²T Pulsar 4 series of detection systems are designed for continuous and instantaneous measurement of Refractory Temperature (RT), Gas Temperature (GT) or Integrated Temperature (FF) in the vessel away from the heat, vibration and corrosive gases. Each system allows visual inspection of combustion processes, refractory cure out and preventative maintenance while the vessel is pressurized and fully operational. The Advanced model is used for monitoring complex processes, such as O₂ enrichment, which normally involve higher temperatures and demand close monitoring.

Operation Temperature Ranges:

The ambient operating temperature range of the Pulsar 4 range is -40°C to 60°C. Process temperature range is 350°C to 2000°C.

Electrical data:

The Pulsar 4 models can be configured as 24V dc, 115V ac or 230V ac, 90W.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- 1. Contact manufacturer for flamepath joint design information.
- The cable glands, cable sealing device or blanking plugs for the unused entries (as applicable) shall be suitably certified with a minimum Ex rating of Ex db IIB+H₂ Gb Ta = -40°C to 60°C.
- 3. In order to maintain an IP66 rating for the equipment, the cable glands shall be suitably certified with a minimum rating of IP66.
- 4. To reduce the risk due to electrostatic discharge, the user shall regularly clean the enclosures with a damp cloth to limit dust layers on the enclosure sides.
- 5. The socket head screws used on the enclosure shall be stainless steel screws grade A4-70 Stainless M8 Socket Head Cap / Allen Screws with minimum yield strength 800MPa.



Certificate No.: IECEx FME 14.0001X

Date of issue: 2019-11-30

Page 4 of 4

Issue No: 5

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Issue 5: Documentation update due to the removal of the ¼ inch threaded holes on the enclosure; Notified Body number change on label and manual documents for ATEX and update to latest standard editions.